



1. REINFORCED PRECAST CONCRETE SHALL HAVE A COMPRESSIVE STRENGTH OF 5000 PSI AT 28 DAYS.

2. 18" DIA. RISER AVAILABLE IN 12" + 24" HEIGHTS.
3. CONSTRUCTION JOINT TO BE SEALED WITH 1" CONSEAL CS-101.

MACK INDUSTRIES, INC. 201 COLUMBIA ROAD, VALLEY CITY, OHIO 44280

ALTERNATE APPROVED SEPTIC TANK SUPPLIER MAY BE USED PER

OWNER/ENGINEER/CONTRACTOR/SUPPLIER AGREEMENT.
CONTRACTOR IS TO NOTIFY ENGINEER OF CHANGES PRIOR TO
PURCHASE & CONSTRUCTION.

CONTRACTOR MAY USE SEPARATE 1000 GALLON SEPTIC TANKS.

Ohio Department of Health(ODH) Treatment Tank Diagram website link/O & M pdf: http://www.odh.ohio.gov/ASSETS/8D627EEE2B7F45549F39415709583A91/aerationIst.PDF



HESS & ASSOCIATES ENGINEERING INC. 12121 KINSMAN ROAD NEWBURY, OHIO 44065

Telephone: (440) 564-8008 Fax: (440) 564-8176

PREPARED UNDER THE SUPERVISION OF:



Michael & Nicole Carlisle Property HOUSEHOLD SEWAGE TREATMENT & ONSITE DISPOSAL SYSTEM PRETREATMENT COMPONENT DETAIL

10180 Orchard Drive Parcel #20A022E000040 Lake County-State of Ohio

Site Address:

Otero Signature Homes 8859 E. Washington St. Bainbridge, OH (216) 346-7301

HESS Project #11-079 DESIGNED BY: MT DRAWN BY : MT GJH 9/2011 : N/A H. : N/A V. CHECKED BY: DATE